




Detail Gradation Statistical Summary Report

Plant 1130-Green Bay Mine (FDOT Pit #16-608)
Product 1009-Concrete Sand
Specification
Period 10/25/2018 - 11/01/2018

Sieve/Test	Tests	Average	Min	Max	Range	St Dev	Target	Specification	PWS
#4 (4.75mm)	5	0.0	0.0	0.0	0.0	0.00			
#8 (2.36mm)	5	0.1	0.1	0.1	0.0	0.00			
#16 (1.18mm)	5	6.3	5.1	7.8	2.7	0.96			
#30 (0.6mm)	5	33.7	29.8	36.7	6.9	2.54			
#50 (0.3mm)	5	66.6	63.1	73.3	10.2	4.17			
#100 (0.15mm)	5	97.2	95.4	98.8	3.4	1.47			
#200 (75µm)	5	99.9	99.8	99.9	0.1	0.04			
Pan	5	100.0	100.0	100.0	0.0	0.00			
Total Moisture	5	2.9	2.1	3.6	1.5	0.57			
FM	5	2.04	1.97	2.14	0.17	0.073			



Comments

Query Query Selections
 Date Created 11/01/2018
 Date Range 10/25/2018 - 11/01/2018
 Plant Green Bay Mine (FDOT Pit #16-608)-1130
 Sample Type Shipping