




Detail Gradation Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1008-Mason Sand
Specification
Period 10/25/2018 - 11/01/2018

Sieve/Test	Tests	Average	Min	Max	Range	St Dev	Target	Specification	PWS
#4 (4.75mm)	5	0	0	0	0	0.0			
#8 (2.36mm)	5	0	0	0	0	0.0			
#16 (1.18mm)	5	0	0	0	0	0.0			
#30 (0.6mm)	5	3	1	5	4	1.8			
#50 (0.3mm)	5	18	14	20	6	2.4			
#100 (0.15mm)	5	82	81	85	4	1.7			
#200 (75µm)	5	99.3	99.2	99.4	0.2	0.07			
Pan	5	100.0	100.0	100.0	0.0	0.00			
FM	5	1.03	0.98	1.06	0.08	0.037			
Total Moisture	5	4.8	4.2	5.9	1.7	0.76			
Color	2	2	1	2	1	0.7			



Comments

Query Query Selections
 Date Created 11/01/2018
 Date Range 10/25/2018 - 11/01/2018
 Plant Haines City Mine (FDOT Pit #16-024)-1030
 Sample Type Shipping