




Detail Gradation Statistical Summary Report

Plant 1130-Green Bay Mine (FDOT Pit #16-608)
Product 1008-Mason Sand
Specification
Period 12/20/2018 - 12/27/2018

Sieve/Test	Tests	Average	Min	Max	Range	St Dev	Target	Specification	PWS
#4 (4.75mm)	3	0	0	0	0	0.0			
#8 (2.36mm)	3	0	0	0	0	0.0			
#16 (1.18mm)	3	1	1	2	1	0.6			
#30 (0.6mm)	3	11	10	13	3	1.5			
#50 (0.3mm)	3	34	31	36	5	2.5			
#100 (0.15mm)	3	91	90	93	3	1.5			
#200 (75µm)	3	99.7	99.6	99.8	0.2	0.12			
Pan	3	100.0	100.0	100.0	0.0	0.00			
Total Moisture	3	5.6	4.0	8.3	4.3	2.33			
FM	3	1.38	1.32	1.42	0.10	0.051			



Comments

Query Query Selections
 Date Created 12/27/2018
 Date Range 12/20/2018 - 12/27/2018
 Plant Green Bay Mine (FDOT Pit #16-608)-1130
 Sample Type Shipping