




# Basic Quality Statistical Summary Report

**Plant** 1070-Independent South Mine (FDOT Pit#11-298)  
**Product** 1001-FDOT Concrete Silica Sand Code F01  
**Specification** FLDOT Silica Sand  
**Period** 08/29/2019 - 09/05/2019

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	5	100	0.0	95-100	95-100
#8 (2.36mm)	5	100	0.4	85-100	85-100
#16 (1.18mm)	5	92	0.8	67-96	65-97
#30 (0.6mm)	5	64	1.9	27-68	25-70
#50 (0.3mm)	5	21	2.7	7-33	5-35
#100 (0.15mm)	5	3	0.9	0-7	0-7
#200 (75µm)	5	0	0.0	0-4	0-4
Pan	5	0	0.0		
FM	5	2.206	0.0577	2.08-2.4\2.25	2.05-2.45



**Query** Query Selections  
 Date Created 09/05/2019  
 Date Range 08/29/2019 - 09/05/2019  
 Plant Independent South Mine (FDOT Pit#11-298)