




Basic Quality Statistical Summary Report

Plant 1210-Liberty Sand Mine
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FLDOT Silica Sand
Period 03/19/2020 - 03/26/2020

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	2	99	0.0		95-100
#8 (2.36mm)	2	92	0.7		85-100
#16 (1.18mm)	2	73	1.4		65-97
#30 (0.6mm)	2	46	1.4		25-70
#50 (0.3mm)	2	18	1.4		5-35
#100 (0.15mm)	2	4	0.7		0-7
#200 (75µm)	2	0.18	0.014		0-4
Pan	2	0.00	0.000		
FM	2	2.66	0.007	2.67-3.02\2.85	2.65-3.05
Total Moisture	2	2.9	0.42		



Query Query Selections
 Date Created 03/26/2020
 Date Range 03/19/2020 - 03/26/2020
 Plant Liberty Sand Mine
 Sample Type Shipping
 Agency Florida DOT MAC