




Detail Gradation Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1009-Concrete Sand
Specification Concrete Sand
Period 12/10/2020 - 12/17/2020

Sieve/Test	Tests	Average	Min	Max	Range	St Dev	Target	Specification	PWS
#4 (4.75mm)	5	100.0	100.0	100.0	0.0	0.00	95-100	95-100	100.0
#8 (2.36mm)	5	99.9	99.8	99.9	0.1	0.04	85-100	85-100	100.0
#16 (1.18mm)	5	95.9	94.6	97.1	2.5	0.99	65-98	65-100	100.0
#30 (0.6mm)	5	71.6	65.9	78.1	12.2	5.70	25-75	>25	100.0
#50 (0.3mm)	5	34.3	27.2	40.9	13.7	5.59	5-44	5-45	97.2
#100 (0.15mm)	5	4.3	2.0	7.5	5.5	2.00	0-10	0-10	99.8
#200 (75µm)	5	0.1	0.1	0.2	0.1	0.04	0-4	0-4	100.0
Pan	5	0.0	0.0	0.0	0.0	0.00			
FM	5	1.94	1.85	2.07	0.22	0.114	1.8-2.2	2	
Total Moisture	5	3.1	1.9	3.6	1.7	0.73	0-5	0-6	100.0



Comments

Query Query Selections
 Date Created 12/17/2020
 Date Range 12/10/2020 - 12/17/2020
 Plant Haines City Mine (FDOT Pit #16-024)
 Sample Type Shipping