




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1009-Concrete Sand
Specification Concrete Sand
Period 05/04/2021 - 05/11/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	3	100.0	0.00	95-100	95-100
#8 (2.36mm)	3	99.8	0.10	85-100	85-100
#16 (1.18mm)	3	94.2	1.15	65-98	65-100
#30 (0.6mm)	3	66.1	3.31	25-75	>25
#50 (0.3mm)	3	31.4	2.82	5-44	5-45
#100 (0.15mm)	3	5.7	1.53	0-10	0-10
#200 (75µm)	3	0.3	0.17	0-4	0-4
Pan	3	0.0	0.00		
FM	3	2.03	0.085	1.8-2.2\2	
Total Moisture	2	2.2	1.41	0-5	0-6



Query Query Selections
 Date Created 05/11/2021
 Date Range 05/04/2021 - 05/11/2021
 Plant Haines City Mine (FDOT Pit #16-024)
 Sample Type Shipping