




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 05/04/2021 - 05/11/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	9	100	0.0		95-100
#8 (2.36mm)	9	100	0.0		85-100
#16 (1.18mm)	9	94	0.9		65-97
#30 (0.6mm)	9	59	2.3	27-68	25-70
#50 (0.3mm)	9	25	4.2	7-34	5-35
#100 (0.15mm)	9	5	1.2	0-6	0-7
#200 (75µm)	9	0	0.0		0-4
Pan	9	0	0.0		
FM	9	2.17	0.066	2.05-2.37	2-2.4
Total Moisture	6	2.7	0.69		



Query Query Selections
 Date Created 05/11/2021
 Date Range 05/04/2021 - 05/11/2021
 Plant Haines City Mine (FDOT Pit #16-024)
 Sample Type Shipping