




Basic Quality Statistical Summary Report

Plant 1210-Liberty Sand Mine
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FLDOT Silica Sand
Period 05/04/2021 - 05/11/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	5	99	0.0		95-100
#8 (2.36mm)	5	92	0.7		85-100
#16 (1.18mm)	5	71	1.2		65-97
#30 (0.6mm)	5	39	3.4		25-70
#50 (0.3mm)	5	15	3.7		5-35
#100 (0.15mm)	5	4	1.3		0-7
#200 (75µm)	5	0.10	0.061		0-4
Pan	5	0.00	0.000		
FM	5	2.81	0.092	2.67-3.02\2.85	2.65-3.05
Total Moisture	5	2.7	0.48		



Query Query Selections
 Date Created 05/11/2021
 Date Range 05/04/2021 - 05/11/2021
 Plant Liberty Sand Mine
 Sample Type Shipping