




Basic Quality Statistical Summary Report

Plant 1070-Independent South Mine (FDOT Pit#11-298)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FLDOT Silica Sand
Period 09/08/2021 - 09/15/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	6	100	0.0	95-100	95-100
#8 (2.36mm)	6	99	0.5	85-100	85-100
#16 (1.18mm)	6	93	0.8	67-96	65-97
#30 (0.6mm)	6	65	2.7	27-68	25-70
#50 (0.3mm)	6	24	4.9	7-33	5-35
#100 (0.15mm)	6	3	0.4	0-7	0-7
#200 (75µm)	6	0	0.0	0-4	0-4
Pan	6	0	0.0		
FM	6	2.161	0.0875	2.08-2.4\2.25	2.05-2.45



Query Query Selections
 Date Created 09/15/2021
 Date Range 09/08/2021 - 09/15/2021
 Plant Independent South Mine (FDOT Pit#11-298)
 Sample Type Shipping