




Basic Quality Statistical Summary Report

Plant 1130-Green Bay Mine (FDOT Pit #16-608)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FLDOT Silica Sand
Period 09/08/2021 - 09/15/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	12	100	0.0	95-100	95-100
#8 (2.36mm)	12	100	0.0	85-100	85-100
#16 (1.18mm)	12	92	0.8	67-96	65-97
#30 (0.6mm)	12	58	4.1	27-68	25-70
#50 (0.3mm)	12	24	3.1	7-33	5-35
#100 (0.15mm)	12	1	0.4	0-6	0-7
#200 (75µm)	12	0	0.0	0-4	0-4
Pan	12	0	0.0		
FM	12	2.25	0.079	2.3	2.1-2.5



Query Query Selections
 Date Created 09/15/2021
 Date Range 09/08/2021 - 09/15/2021
 Plant Green Bay Mine (FDOT Pit #16-608)
 Sample Type Shipping