




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1009-Concrete Sand
Specification Concrete Sand
Period 09/02/2021 - 09/09/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	2	100.0	0.00	95-100	95-100
#8 (2.36mm)	2	99.7	0.14	85-100	85-100
#16 (1.18mm)	2	91.6	0.42	65-98	65-100
#30 (0.6mm)	2	59.6	1.41	25-75	>25
#50 (0.3mm)	2	27.8	5.30	5-44	5-45
#100 (0.15mm)	2	5.6	0.21	0-10	0-10
#200 (75µm)	2	0.2	0.07	0-4	0-4
Pan	2	0.0	0.00		
FM	2	2.16	0.078	1.8-2.2\2	
Total Moisture	2	3.6	2.33	0-5	0-6



Query Query Selections
 Date Created 09/09/2021
 Date Range 09/02/2021 - 09/09/2021
 Plant Haines City Mine (FDOT Pit #16-024)
 Sample Type Shipping