




Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 09/08/2021 - 09/15/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	12	100.0	0.00		95-100
#8 (2.36mm)	12	99.8	0.03		85-100
#16 (1.18mm)	12	94.7	0.44	67-96	65-97
#30 (0.6mm)	12	46.0	2.10	27-68	25-70
#50 (0.3mm)	12	12.4	2.16		5-35
#100 (0.15mm)	12	1.4	1.62		0-7
#200 (75µm)	12	0.0	0.00		
Pan	12	0.0	0.00		
FM	12	2.46	0.044	2.22-2.57/2.4	2.2-2.6



Query Query Selections
 Date Created 09/15/2021
 Date Range 09/08/2021 - 09/15/2021
 Plant Ortona Sand Company (FDOT Pit # 05-045)
 Sample Type Shipping