




Basic Quality Statistical Summary Report

Plant 1210-Liberty Sand Mine
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FLDOT Silica Sand
Period 09/02/2021 - 09/09/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	2	98	0.7		95-100
#8 (2.36mm)	2	90	2.1		85-100
#16 (1.18mm)	2	68	2.1		65-97
#30 (0.6mm)	2	36	6.4		25-70
#50 (0.3mm)	2	17	5.7		5-35
#100 (0.15mm)	2	4	1.4		0-7
#200 (75µm)	2	0.20	0.113		0-4
Pan	2	0.00	0.000		
FM	2	2.85	0.170	2.67-3.02\2.85	2.65-3.05
Total Moisture	2	2.4	1.13		



Query Query Selections
 Date Created 09/09/2021
 Date Range 09/02/2021 - 09/09/2021
 Plant Liberty Sand Mine
 Sample Type Shipping
 Agency Florida DOT MAC