




Basic Quality Statistical Summary Report

Plant 1070-Independent South Mine (FDOT Pit#11-298)
Product 1008-Mason Sand
Specification Mason Sand
Period 10/28/2021 - 11/04/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	6	100	0.0	97-100	
#8 (2.36mm)	6	100	0.0	97-100	
#16 (1.18mm)	6	100	0.8	95-100	
#30 (0.6mm)	6	97	4.6	85-100	
#50 (0.3mm)	6	84	11.9	35-90	
#100 (0.15mm)	6	20	6.2	0-35	
#200 (75µm)	6	0.6	0.24		
Pan	6	0.0	0.00		
FM	6	0.981	0.2223	1.05-1.45\1.2	



Query Query Selections
 Date Created 11/04/2021
 Date Range 10/28/2021 - 11/04/2021
 Plant Independent South Mine (FDOT Pit#11-298)
 Sample Type Shipping