




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 10/28/2021 - 11/04/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	4	100	0.0		95-100
#8 (2.36mm)	4	100	0.0		85-100
#16 (1.18mm)	4	93	0.8		65-97
#30 (0.6mm)	4	61	1.0	27-68	25-70
#50 (0.3mm)	4	30	0.5	7-34	5-35
#100 (0.15mm)	4	6	0.5	0-6	0-7
#200 (75µm)	4	0	0.0		0-4
Pan	4	0	0.0		
FM	4	2.09	0.014	2.05-2.37	2-2.4
Total Moisture	4	3.2	0.45		



Query Query Selections
 Date Created 11/04/2021
 Date Range 10/28/2021 - 11/04/2021
 Plant Haines City Mine (FDOT Pit #16-024)
 Sample Type Shipping
 Agency Florida DOT MAC