




Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 10/28/2021 - 11/04/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	6	100.0	0.00		95-100
#8 (2.36mm)	6	99.9	0.04		85-100
#16 (1.18mm)	6	95.3	0.55	67-96	65-97
#30 (0.6mm)	6	45.2	2.98	27-68	25-70
#50 (0.3mm)	6	8.8	1.61		5-35
#100 (0.15mm)	6	0.8	0.79		0-7
#200 (75µm)	6	0.0	0.00		
Pan	6	0.0	0.00		
FM	6	2.50	0.043	2.22-2.57	2.2-2.6
Total Moisture	6	3.1	0.26		



Query Query Selections
 Date Created 11/04/2021
 Date Range 10/28/2021 - 11/04/2021
 Plant Ortona Sand Company (FDOT Pit # 05-045)
 Sample Type Shipping
 Agency Florida DOT MAC