




Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1008-Mason Sand
Specification Mason Sand
Period 10/28/2021 - 11/04/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	4	100	0.0	100-100	
#8 (2.36mm)	5	100	0.0	100-100	
#16 (1.18mm)	5	100	0.0	97-100	
#30 (0.6mm)	5	96	1.9	80-100	
#50 (0.3mm)	5	59	7.3	43-85	
#100 (0.15mm)	5	6	0.9	0-25	
#200 (75µm)	5	0.0	0.04		
Pan	5	0.0	0.00		
FM	5	1.39	0.100		
Total Moisture	5	4.2	1.31	0-5	0-6



Query Query Selections
 Date Created 11/04/2021
 Date Range 10/28/2021 - 11/04/2021
 Plant Ortona Sand Company (FDOT Pit # 05-045)
 Sample Type Shipping