




Basic Quality Statistical Summary Report

Plant 1070-Independent South Mine (FDOT Pit#11-298)
Product 1008-Mason Sand
Specification Mason Sand
Period 12/09/2021 - 12/16/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	1	100		97-100	
#8 (2.36mm)	1	100		97-100	
#16 (1.18mm)	1	100		95-100	
#30 (0.6mm)	1	100		85-100	
#50 (0.3mm)	1	94		35-90	
#100 (0.15mm)	1	23		0-35	
#200 (75µm)	1	0.6			
Pan	1	0.0			
FM	1	0.832		1.05-1.45\1.2	



Query Query Selections
 Date Created 12/16/2021
 Date Range 12/09/2021 - 12/16/2021
 Plant Independent South Mine (FDOT Pit#11-298)
 Sample Type Shipping