




Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1008-Mason Sand
Specification Mason Sand
Period 12/23/2021 - 12/30/2021

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	4	100	0.0	100-100	
#8 (2.36mm)	4	100	0.0	100-100	
#16 (1.18mm)	4	96	1.7	97-100	
#30 (0.6mm)	4	67	3.9	80-100	
#50 (0.3mm)	4	42	7.1	43-85	
#100 (0.15mm)	4	13	6.7	0-25	
#200 (75µm)	4	0.4	0.33		
Pan	4	0.0	0.00		
FM	4	1.82	0.095		
Total Moisture	4	4.0	0.70	0-5	0-6



Query Query Selections
 Date Created 12/30/2021
 Date Range 12/23/2021 - 12/30/2021
 Plant Ortona Sand Company (FDOT Pit # 05-045)
 Sample Type Shipping