




Basic Quality Statistical Summary Report

Plant 1130-Green Bay Mine (FDOT Pit #16-608)
Product 1008-Mason Sand
Specification Mason Sand
Period 09/11/2022 - 09/17/2022

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	2	100	0.0	97-100	
#8 (2.36mm)	2	100	0.0	97-100	
#16 (1.18mm)	2	100	0.7	95-100	
#30 (0.6mm)	2	96	0.0	85-100	
#50 (0.3mm)	2	85	0.0	35-90	
#100 (0.15mm)	2	8	1.4	3-35	
#200 (75µm)	2	0.0	0.00		
Pan	2	0.0	0.00		
FM	2	1.11	0.028	0.9-1.4	1.2



Query Query Selections
 Date Created 09/21/2022
 Date Range 09/11/2022 - 09/17/2022
 Plant Green Bay Mine (FDOT Pit #16-608)
 Sample Type Shipping