




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 09/11/2022 - 09/17/2022

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	10	100	0.0		95-100
#8 (2.36mm)	10	100	0.0		85-100
#16 (1.18mm)	10	93	1.1		65-97
#30 (0.6mm)	10	54	4.9	27-68	25-70
#50 (0.3mm)	10	21	5.6	7-34	5-35
#100 (0.15mm)	10	5	0.9	0-6	0-7
#200 (75µm)	10	0	0.0		0-4
Pan	10	0	0.0		
FM	10	2.26	0.124	2.05-2.37/2.2	2-2.4



Query Query Selections
 Date Created 09/21/2022
 Date Range 09/11/2022 - 09/17/2022
 Plant Haines City Mine (FDOT Pit #16-024)
 Sample Type Shipping