




Basic Quality Statistical Summary Report

Plant 1070-Independent South Mine (FDOT Pit#11-298)
Product 1008-Mason Sand
Specification Mason Sand
Period 09/11/2022 - 09/17/2022

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	9	100	0.0	97-100	
#8 (2.36mm)	9	100	0.0	97-100	
#16 (1.18mm)	9	100	0.0	95-100	
#30 (0.6mm)	9	100	0.3	85-100	
#50 (0.3mm)	9	86	6.2	35-90	
#100 (0.15mm)	9	24	4.3	0-35	
#200 (75µm)	9	0.7	0.16		
Pan	9	0.0	0.00		
FM	9	0.904	0.1055	1.05-1.45\1.2	



Query Query Selections
 Date Created 09/21/2022
 Date Range 09/11/2022 - 09/17/2022
 Plant Independent South Mine (FDOT Pit#11-298)
 Sample Type Shipping