




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 10/18/2022 - 10/25/2022

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	7	100	0.0		95-100
#8 (2.36mm)	7	100	0.0		85-100
#16 (1.18mm)	7	93	1.0		65-97
#30 (.6mm)	7	55	2.9	27-68	25-70
#50 (.3mm)	7	22	2.8	7-34	5-35
#100 (.15mm)	7	4	0.9	0-6	0-7
#200 (75µm)	7	0	0.0		0-4
Pan	7	0	0.0		
FM	7	2.26	0.072	2.05-2.37	2-2.4
Total Moisture	7	2.7	0.37		
Color	1	1		1-2	1-3



Query

Query Selections
Date Created 10/25/2022
Date Range 10/18/2022 - 10/25/2022
Plant Haines City Mine (FDOT Pit #16-024)
Sample Type Shipping
Agency Florida DOT MAC