




# Basic Quality Statistical Summary Report

**Plant** 2010-Ortona Sand Company (FDOT Pit # 05-045)  
**Product** 1001-FDOT Concrete Silica Sand Code F01  
**Specification** FDOT Concrete Silica Sand Code F01  
**Period** 12/27/2022 - 01/03/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	9	100.0	0.00		95-100
#8 (2.36mm)	9	99.9	0.08		85-100
#16 (1.18mm)	9	94.9	0.71	67-96	65-97
#30 (.6mm)	9	45.4	2.87	27-68	25-70
#50 (.3mm)	9	11.2	2.26		5-35
#100 (.15mm)	9	0.5	0.21		0-7
#200 (75µm)	9	0.0	0.04		
Pan	9	0.0	0.00		
FM	9	2.48	0.050	2.22-2.57/2.4	2.2-2.6



**Query**

Query Selections  
Date Created 01/04/2023  
Date Range 12/27/2022 - 01/03/2023  
Plant Ortona Sand Company (FDOT Pit # 05-045)  
Sample Type Shipping