



01/04/2023

To Whom it may concern,

This material is currently produced at our "Ortona" facility (FDOT mine #05-045) this material is shipped and produced utilizing an approved quality control plan. The fine aggregate "Mason Sand" product number (1008) is a washed and graded product. Each load is accompanied by an individual ticket.

1008-Mason Sand

| Procedure | Sieve/Test | Average | Unit | Mason Sand |
|------------|--------------|---------|------|------------|
| | #4 (4.75mm) | 100 | % | |
| | #8 (2.36mm) | 100 | % | |
| | #16 (1.18mm) | 97 | % | |
| | #30 (.6mm) | 78 | % | |
| | #50 (.3mm) | 50 | % | |
| | #100 (.15mm) | 6 | % | |
| | #200 (75µm) | 0.1 | % | |
| ASTM C-136 | FM | 1.69 | | |

Sincerely,

Mario Cardenas

Quality Control Manager
E.R. Jahna Ind, Inc.
Office: 352-394-7455
Cell: 863-528-2335
Fax: 352-394-8730

Name/Title Mario Cardenas / Quality Control Manager