



Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 02/15/2023 - 02/22/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	8	100	0.0		95-100
#8 (2.36mm)	8	100	0.0		85-100
#16 (1.18mm)	8	94	0.6		65-97
#30 (.6mm)	8	58	2.4	27-68	25-70
#50 (.3mm)	8	27	2.5	7-34	5-35
#100 (.15mm)	8	6	0.8	0-6	0-7
#200 (75µm)	8	0	0.0		0-4
Pan	8	0	0.0		
FM	8	2.15	0.049	2.05-2.37\2.2	2-2.4
-#200 (75um)	1	0.16			
Grad Loss	8	0.054	0.0507		
Wash Loss (#200/75um)	1	0.05			
Total Moisture	5	3.0	0.28		
Color	1	1		1-2\1	1-3

Query

Query Selections

Date Created 02/22/2023

Date Range 02/15/2023 - 02/22/2023

Plant Haines City Mine (FDOT Pit #16-024)

Sample Type Shipping