



Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1008-Mason Sand
Specification Mason Sand
Period 02/15/2023 - 02/22/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	4	100	0.0	100-100	
#8 (2.36mm)	4	100	0.0	100-100	
#16 (1.18mm)	4	98	1.0	97-100	
#30 (.6mm)	4	73	9.7	80-100	
#50 (.3mm)	4	55	1.3	43-85	
#100 (.15mm)	4	8	7.8	0-25	
#200 (75µm)	4	0.1	0.00		
Pan	4	0.0	0.00		
FM	4	1.66	0.021		
Grad Loss	4	0.008	0.0155		
Total Moisture	4	3.9	0.10	0-5	0-6

Query

Query Selections
Date Created 02/22/2023
Date Range 02/15/2023 - 02/22/2023
Plant Ortona Sand Company (FDOT Pit # 05-045)
Sample Type Shipping