



02/01/2023 – 02/28/2023

To Whom it may concern,

This material is currently produced at our "Haines City" facility (FDOT mine #16-024) this material is shipped and produced utilizing an approved quality control plan. The fine aggregate "Mason Sand" product number (1008) is a washed and graded product. Each load is accompanied by an individual ticket.

### 1008-Mason Sand

| Procedure  | Sieve/Test     | Average | Unit | Mason Sand |
|------------|----------------|---------|------|------------|
|            | #4 (4.75mm)    | 100     | %    |            |
|            | #8 (2.36mm)    | 100     | %    |            |
|            | #16 (1.18mm)   | 100     | %    |            |
|            | #30 (.6mm)     | 95      | %    |            |
|            | #50 (.3mm)     | 73      | %    |            |
|            | #100 (.15mm)   | 14      | %    |            |
|            | #200 (75µm)    | 0.1     | %    |            |
| ASTM C-136 | FM             | 1.17    |      |            |
| ASTM C-566 | Total Moisture | 5.3     | %    | 0.0-7.0    |
| T-21/ C-40 | Color          | 1       |      |            |

Sincerely,

Mario Cardenas Quality  
Control Manager E.R.  
Jahna Ind, Inc.  
Office: 352-394-7455  
Cell: 863-557-0342  
Fax: 352-394-8730

Name/Title

David Clements / Mine manager