




Basic Quality Statistical Summary Report

Plant 1130-Green Bay Mine (FDOT Pit #16-608)
Product 1008-Mason Sand
Specification Mason Sand
Period 05/01/2023 - 05/10/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	6	100	0.0	97-100	
#8 (2.36mm)	6	100	0.0	97-100	
#16 (1.18mm)	6	100	0.4	95-100	
#30 (.6mm)	6	97	1.0	85-100	
#50 (.3mm)	6	72	2.4	35-90	
#100 (.15mm)	6	7	1.5	3-35	
#200 (75µm)	6	0.0	0.05		
Pan	6	0.0	0.00		
FM	6	1.25	0.030	0.9-1.4	1.2



Query

Query Selections

Date Created 05/10/2023

Date Range 05/01/2023 - 05/10/2023

Plant Green Bay Mine (FDOT Pit #16-608)

Sample Type Shipping