




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1009-Concrete Sand
Specification Concrete Sand
Period 05/01/2023 - 05/10/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	8	100.0	0.00	95-100	95-100
#8 (2.36mm)	8	100.0	0.04	85-100	85-100
#16 (1.18mm)	8	97.8	1.14	65-98	65-100
#30 (.6mm)	8	81.2	7.00	25-75	≥25
#50 (.3mm)	8	40.7	7.33	5-44	5-45
#100 (.15mm)	8	6.4	3.99	0-10	0-10
#200 (75µm)	8	0.1	0.05	0-4	0-4
Pan	8	0.0	0.00		
FM	8	1.74	0.084	1.8-2.2\2	



Query

Query Selections

Date Created 05/10/2023

Date Range 05/01/2023 - 05/10/2023

Plant Haines City Mine (FDOT Pit #16-024)

Sample Type Shipping