




# Basic Quality Statistical Summary Report

**Plant** 2010-Ortona Sand Company (FDOT Pit # 05-045)  
**Product** 1009-Concrete Sand  
**Specification** Concrete Sand  
**Period** 05/01/2023 - 05/10/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	5	100.0	0.00	95-100	
#8 (2.36mm)	5	99.9	0.00	85-100	
#16 (1.18mm)	5	96.6	1.06	65-99	
#30 (.6mm)	5	62.7	5.49	25-70	
#50 (.3mm)	5	35.8	8.76	5-35	
#100 (.15mm)	5	6.6	3.38	0-7	
#200 (75µm)	5	0.1	0.08		
Pan	5	0.0	0.00		
FM	5	1.99	0.066		



**Query**

Query Selections  
Date Created 05/10/2023  
Date Range 05/01/2023 - 05/10/2023  
Plant Ortona Sand Company (FDOT Pit # 05-045)  
Sample Type Shipping