




Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 05/01/2023 - 05/10/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	9	100.0	0.00		95-100
#8 (2.36mm)	9	99.9	0.07		85-100
#16 (1.18mm)	9	95.0	0.58	67-96	65-97
#30 (.6mm)	9	49.1	1.71	27-68	25-70
#50 (.3mm)	9	13.1	2.20		5-35
#100 (.15mm)	9	0.8	0.44		0-7
#200 (75µm)	9	0.0	0.00		
Pan	9	0.0	0.00		
FM	9	2.42	0.031	2.22-2.57/2.4	2.2-2.6



Query

Query Selections
Date Created 05/10/2023
Date Range 05/01/2023 - 05/10/2023
Plant Ortona Sand Company (FDOT Pit # 05-045)
Sample Type Shipping