




# Basic Quality Statistical Summary Report

**Plant** 2010-Ortona Sand Company (FDOT Pit # 05-045)  
**Product** 1008-Mason Sand  
**Specification** Mason Sand  
**Period** 05/01/2023 - 05/10/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	6	100	0.0	100-100	
#8 (2.36mm)	6	100	0.0	100-100	
#16 (1.18mm)	6	99	0.5	97-100	
#30 (.6mm)	6	85	2.2	80-100	
#50 (.3mm)	6	51	3.1	43-85	
#100 (.15mm)	6	5	1.3	0-25	
#200 (75µm)	6	0.1	0.04		
Pan	6	0.0	0.00		
FM	6	1.60	0.023		



**Query**

Query Selections  
Date Created 05/10/2023  
Date Range 05/01/2023 - 05/10/2023  
Plant Ortona Sand Company (FDOT Pit # 05-045)  
Sample Type Shipping