




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 12/22/2023 - 12/29/2023

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	1	100			95-100
#8 (2.36mm)	1	100			85-100
#16 (1.18mm)	1	95			65-97
#30 (.6mm)	1	63		27-68	25-70
#50 (.3mm)	1	30		7-34	5-35
#100 (.15mm)	1	7		0-6	0-7
#200 (75µm)	1	0			0-4
Pan	1	0			
FM	1	2.06		2.05-2.37	2-2.4
Total Moisture	1	2.0			



Tests: 1 D10(ES): 0.164 D15: 0.191 D30: 0.300 D50: 0.457 D60: 0.563 D85: 0.955 D90: 1.062 Cu: 3.431 Cc: 0.973

Query

Query Selections

Date Created 12/29/2023

Date Range 12/22/2023 - 12/29/2023

Plant Haines City Mine (FDOT Pit #16-024)

Sample Type Shipping

Agency Florida DOT MAC