




# Basic Quality Statistical Summary Report

**Plant** 2010-Ortona Sand Company (FDOT Pit # 05-045)  
**Product** 1008-Mason Sand  
**Specification** Mason Sand  
**Period** 01/26/2024 - 02/02/2024

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	5	100	0.0	100-100	
#8 (2.36mm)	5	100	0.0	100-100	
#16 (1.18mm)	5	97	0.4	97-100	
#30 (.6mm)	5	71	5.9	80-100	
#50 (.3mm)	5	39	4.2	43-85	
#100 (.15mm)	5	6	4.4	0-25	
#200 (75µm)	5	0.1	0.00		
Pan	5	0.0	0.00		
FM	5	1.87	0.050		
Total Moisture	5	3.8	0.18	0-5	0-6



**Query**

Query Selections  
Date Created 02/02/2024  
Date Range 01/26/2024 - 02/02/2024  
Plant Ortona Sand Company (FDOT Pit # 05-045)  
Sample Type Shipping