




# Basic Quality Statistical Summary Report

**Plant** 1210-Liberty Sand Mine  
**Product** 1001-FDOT Concrete Silica Sand Code F01  
**Specification** FLDOT Silica Sand  
**Period** 03/29/2024 - 04/05/2024

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	11	99	0.5		95-100
#8 (2.36mm)	11	91	0.7		85-100
#16 (1.18mm)	11	68	3.3		65-97
#30 (.6mm)	11	39	5.4		25-70
#50 (.3mm)	11	19	4.4		5-35
#100 (.15mm)	11	4	1.3		0-7
#200 (75µm)	11	0.18	0.090		0-4
Pan	11	0.00	0.000		
FM	11	<b>2.81</b>	0.140	2.4-2.8\2.6	2.4-2.8
-#200 (75um)	1	0.29			
Total Moisture	11	4.6	0.94		



**Query**

Query Selections  
Date Created 04/05/2024  
Date Range 03/29/2024 - 04/05/2024  
Plant Liberty Sand Mine  
Sample Type Shipping  
Agency Florida DOT MAC