




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 07/19/2024 - 07/26/2024

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	11	100	0.0		95-100
#8 (2.36mm)	11	100	0.0		85-100
#16 (1.18mm)	11	95	1.1		65-97
#30 (.6mm)	11	60	3.8	27-68	25-70
#50 (.3mm)	11	21	6.0	7-34	5-35
#100 (.15mm)	11	4	1.8	0-6	0-7
#200 (75µm)	11	0	0.0		0-4
Pan	11	0	0.0		
FM	11	2.20	0.113	2.05-2.37	2-2.4
-#200 (75um)	1	0.13			
Grad Loss	11	0.030	0.0649		
Wash Loss (#200/75um)	1	0.13			
Total Moisture	11	2.8	0.76		
Color	1	1		1-2\1	1-3
D10 (ES)	11	0.20	0.034		
D50	11	0.50	0.038		
D60	11	0.60	0.039		
Cc	11	1.03	0.052		
Cu	11	3.02	0.305		



Query

Query Selections
Date Created 07/26/2024
Date Range 07/19/2024 - 07/26/2024
Plant Haines City Mine (FDOT Pit #16-024)
Sample Type Shipping