




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 11/13/2024 - 11/20/2024

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	11	100	0.0		95-100
#8 (2.36mm)	11	100	0.0		85-100
#16 (1.18mm)	11	95	1.4		65-97
#30 (.6mm)	11	61	5.0	27-68	25-70
#50 (.3mm)	11	25	3.8	7-34	5-35
#100 (.15mm)	11	4	1.5	0-6	0-7
#200 (75µm)	11	0	0.0		0-4
Pan	11	0	0.0		
FM	11	2.17	0.078	2.05-2.37	2-2.4
Grad Loss	11	0.015	0.0354		
Total Moisture	11	3.1	1.87		
D10 (ES)	11	0.19	0.013		
D50	11	0.49	0.038		
D60	11	0.60	0.048		
Cc	11	0.98	0.073		
Cu	11	3.21	0.323		



Query

Query Selections

Date Created 11/20/2024

Date Range 11/13/2024 - 11/20/2024

Plant Haines City Mine (FDOT Pit #16-024)

Sample Type Shipping