




Basic Quality Statistical Summary Report

Plant 1210-Savannah Sand Mine
Product 1008-Mason Sand
Specification Mason Sand
Period 04/11/2025 - 04/18/2025

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	4	100	0.0	97-100	
#8 (2.36mm)	4	100	1.0	97-100	
#16 (1.18mm)	4	97	3.4	90-100	
#30 (.6mm)	4	90	10.1	65-100	
#50 (.3mm)	4	71	13.9	35-90	
#100 (.15mm)	4	17	3.6	0-40	
#200 (75µm)	4	0.5	0.13		
Pan	4	0.0	0.00		
FM	4	1.26	0.310		
Total Moisture	4	5.1	2.49	0-6\3	0-7
D10 (ES)	4	0.11	0.010		
D50	4	0.24	0.039		
D60	4	0.28	0.068		
Cc	4	1.05	0.131		
Cu	4	2.47	0.428		



Query

Query Selections
Date Created 04/18/2025
Date Range 04/11/2025 - 04/18/2025
Plant Savannah Sand Mine
Sample Type Shipping