



Product Quality Summary Report

Period 04/02/2025 - 05/02/2025

| | |
|----------------------|---|
| Plant | 1130 Green Bay Mine (FDOT Pit #16-608) |
| Product | 1009 Concrete Sand |
| Specification | Concrete Sand |

| | |
|---------------------------|--------|
| #4 (4.75mm) | 100.0 |
| #8 (2.36mm) | 99.9 |
| #16 (1.18mm) | 96.7 |
| #30 (.6mm) | 74.6 |
| #50 (.3mm) | 39.8 |
| #100 (.15mm) | 3.7 |
| #200 (75µm) | 0.1 |
| Pan | 0.0 |
| FM | 1.85 |
| Grad Loss | 0.013 |
| Absorption (Fine) | 0.1 |
| Total Moisture | 3.8 |
| D10 (ES) | 0.1696 |
| D50 | 0.37 |
| D60 | 0.45 |
| Cc | 0.83 |
| Cu | 2.65 |
| SPGR Fine (Dry, Gsb) | 2.643 |
| SPGR Fine (SSD) | 2.646 |
| SPGR Fine (Apparent, Gsa) | 2.650 |



Product Quality Summary Report

Period 04/02/2025 - 05/02/2025

Query Query Selections
Date Created 05/02/2025
Date Range 04/02/2025 - 05/02/2025
Plant Green Bay Mine (FDOT Pit #16-608)
Sample Type Shipping