



# Product Quality Summary Report

Period 04/02/2025 - 05/02/2025

---

**Plant** 2010  
Ortona Sand  
Company  
(FDOT Pit #  
05-045)

**Product** 1009  
Concrete  
Sand

**Specification** Concrete  
Sand

---

#4 (4.75mm)	100.0
#8 (2.36mm)	99.9
#16 (1.18mm)	95.9
#30 (.6mm)	56.5
#50 (.3mm)	18.2
#100 (.15mm)	1.4
#200 (75µm)	0.1
Pan	0.0
FM	2.28
Absorption (Fine)	0.1
Total Moisture	3.3
D10 (ES)	0.22
D25	0.34
D50	0.54
D60	0.63
D75	0.82
D15/D85	0.27
Cc	1.03
Cu	2.95
SPGR Fine (Dry, Gsb)	2.633
SPGR Fine (SSD)	2.636
SPGR Fine (Apparent, Gsa)	2.640

---



# Product Quality Summary Report

**Period** 04/02/2025 - 05/02/2025

**Query** Query Selections  
Date Created 05/02/2025  
Date Range 04/02/2025 - 05/02/2025  
Plant Ortona Sand Company (FDOT Pit # 05-045)  
Sample Type Shipping