




Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1009-Concrete Sand
Specification Concrete Sand
Period 05/23/2025 - 05/30/2025

| Sieve/Test | Tests | Average | St Dev | Target | Specification |
|----------------|-------|---------|--------|--------|---------------|
| #4 (4.75mm) | 3 | 100.0 | 0.00 | 95-100 | |
| #8 (2.36mm) | 3 | 99.9 | 0.06 | 85-100 | |
| #16 (1.18mm) | 3 | 95.7 | 0.35 | 65-99 | |
| #30 (.6mm) | 3 | 55.4 | 1.76 | 25-70 | |
| #50 (.3mm) | 3 | 19.7 | 3.40 | 5-35 | |
| #100 (.15mm) | 3 | 1.1 | 0.58 | 0-7 | |
| #200 (75µm) | 3 | 0.1 | 0.17 | | |
| Pan | 3 | 0.0 | 0.00 | | |
| FM | 3 | 2.28 | 0.050 | | |
| Total Moisture | 3 | 4.2 | 1.25 | | |
| D10 (ES) | 3 | 0.21 | 0.015 | | |
| D50 | 3 | 0.54 | 0.021 | | |
| D60 | 3 | 0.65 | 0.017 | | |
| D15/D85 | 3 | 0.26 | 0.025 | | |
| Cc | 3 | 0.98 | 0.021 | | |
| Cu | 3 | 3.08 | 0.161 | | |



Query

Query Selections

Date Created 05/30/2025

Date Range 05/23/2025 - 05/30/2025

Plant Ortona Sand Company (FDOT Pit # 05-045)

Sample Type Shipping