



Product Quality Summary Report

Period 05/01/2025 - 05/31/2025

Plant 2010
Ortona Sand
Company
(FDOT Pit #
05-045)

Product 1001
FDOT
Concrete
Silica Sand
Code F01

Specification FDOT
Concrete
Silica Sand
Code F01

#4 (4.75mm)	100.0
#8 (2.36mm)	99.9
#16 (1.18mm)	94.9
#30 (.6mm)	46.8
#50 (.3mm)	10.7
#100 (.15mm)	0.6
#200 (75µm)	0.0
Pan	0.0
FM	2.47
-#200 (75um)	0.07
Absorption	0.2
Absorption (Fine)	0.2
Total Moisture	3.1
Color	2
SPGR Fine (Dry, Gsb)	2.625
SPGR Fine (SSD)	2.630
SPGR Fine (Apparent, Gsa)	2.638



Product Quality Summary Report

Period 05/01/2025 - 05/31/2025

Query Query Selections
Date Created 06/01/2025
Date Range 05/01/2025 - 05/31/2025
Plant Ortona Sand Company (FDOT Pit # 05-045)
Sample Type Shipping
Agency Florida DOT MAC