




# Basic Quality Statistical Summary Report

**Plant** 2010-Ortona Sand Company (FDOT Pit # 05-045)  
**Product** 1009-Concrete Sand  
**Specification** Concrete Sand  
**Period** 06/13/2025 - 06/20/2025

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	6	100.0	0.00	95-100	
#8 (2.36mm)	6	99.8	0.05	85-100	
#16 (1.18mm)	6	96.0	2.18	65-99	
#30 (.6mm)	6	60.4	15.17	25-70	
#50 (.3mm)	6	27.1	14.66	5-35	
#100 (.15mm)	6	2.0	1.05	0-7	
#200 (75µm)	6	0.0	0.04		
Pan	6	0.0	0.00		



**Query**

Query Selections

Date Created 06/20/2025

Date Range 06/13/2025 - 06/20/2025

Plant Ortona Sand Company (FDOT Pit # 05-045)

Product

Specification Auto-Default

Number of Tests 30