



Product Quality Summary Report

Period 09/01/2026 - 09/30/2026

Plant 2010
Ortona Sand
Company
(FDOT Pit #
05-045)

Product 1001
FDOT Concrete
Silica Sand
Code F01

Specification FDOT Concrete
Silica Sand
Code F01

#4 (4.75mm)	100.0
#8 (2.36mm)	99.9
#16 (1.18mm)	95.3
#30 (.6mm)	51.4
#50 (.3mm)	14.2
#100 (.15mm)	0.9
#200 (75µm)	0.2
Pan	0.0
FM	2.383
Wash Loss (#200/75um)	0.266
Absorption (Fine)	0.20
Total Moisture	4.049
Color	2
SPGR Fine (Dry,Gsb)	2.625
SPGR Fine (SSD)	2.630
SPGR Fine (Apparent,Gsa)	2.638



Product Quality Summary Report

Period 09/01/2026 - 09/30/2026

Query Query Selections
Date Created 10/01/2026
Date Range 09/01/2026 - 09/30/2026
Plant Ortona Sand Company (FDOT Pit # 05-045)
Product
Specification Auto-Default